



Manufacturer: AVOID contact of the connector with foreign objects such as wall studs, electrical wiring, copper or iron pipe, paneling, sheet metal, etc. to avoid corrosion. DO NOT use the gas connector or gas supply line for the appliance ground.  
Code: no specific comment



This flex line is not in contact with case



This is how some inspectors think all cases should be done. They recommend all prior flex connections be repaired to this and simply cite it as improper.