

ON-SITE SEWAGE SYSTEM STRESS/DYE TEST PROCEDURE

Conventional Systems Only

1. BF = Bathroom sink faucet 3 gallons per minute
2. KF = Kitchen sink faucet 3 gallons per minute
3. BT = Bathtub faucet 5 gallons per minute
4. Water Closet
 - a. Old Style 5 gallons per flush
 - b. New Style 1.6 gallons per flush
5. Washing machine/per cycle
 - a. Top loader
 - i. Small 15 gallons per load
 - ii. Medium 30 gallons per load
 - iii. Heavy 45 gallons per load
 - b. Side loader 15 gallons per load
6. Dishwasher 8-12 gallons per load